



My Ref: No. NFS/.SAF.D/R21.WC/VOL.III/ 168

Your Ref: No.

27 JULY, 2021


THE MANAGER
GHANA RUBBER ESTATE LIMITED
AWODUA, W/R

RENEWAL – FIRE CERTIFICATE (WC18232 F)

1. The under listed documents on your premises (Workshop/office) have been inspected by an authorized Fire Inspector for the renewal of your Fire Certificate.
 - i) Previous Fire Certificate
 - ii) Log book
2. Re- inspection of your premises shows that:-
 - i) Fire extinguishers installed have been serviced
 - ii) Record of test on fire extinguishers, fire alarm and training entered in the log book has been checked (where appropriate).
3. In addition to the above, you need to provide the following information before the next renewal date:
 - i) Provide the location of the nearest hydrant to the premises
 - ii) Evidence of compulsory Fire Insurance Certificate
 - iii) The quantities of fire facilities installed on premises
 - iv) Confirmation of the type of fire detection and warning system installed (i.e. Battery or Electrical)
4. Management shall ensure that Log book entries are made and installed fire facilities are maintained by a competent Fire Protection Service Contractor/Provider.
5. Your Fire Certificate is hereby renewed and expires in July, 2022.
6. Attached is the new Fire Certificate No. 0032534.

NB:

- FAILURE TO DISPLAY THE FIRE CERTIFICATE IS AN OFFENCE
- FAILURE TO RENEW AN EXPIRED CERTIFICATE IS AN OFFENCE


OBENG DANKWA DWAMENA
DCFO
DIRECTOR FIRE SAFETY
for: CHIEF FIRE OFFICER

0032534



LOW RISK

GHANA NATIONAL FIRE SERVICE



FIRE CERTIFICATE

This is to certify that

house number _____ of AWODUA, W/R _____ has been issued
with Fire Certificate for use as PLACE OF WORK (WORKSHOP/ OFFICE) GHANA
ESTATE LIMITED

Having upon inspection satisfied the following requirement as Fire Safety:

Means of Escape

Type	Number	Location
a) MAIN EXIT	A O D	A O D
b) GFN	2	
c)		
d)		

Fire Fighting Equipment

Type	Number	Location
a) CO2 (3KG)	2	
b) DP (6KG)	4	
c)		
d)		

Fire Hydrant/Source of Water Supply

HYDARNT _____ - NIL
ALTERANTIVE SOURCE O WATER - WATER TNAK /BOREHOLE

Warning Device(s)

Type	Number	Location
a) DS (BATTERY)	11	
b) CPT	2	
c) SDER	2	
d)		

WC18232F

THIS CERTIFICATE IS VALID FOR TWELVE MONTHS

Dated this 14TH day of JULY, 20 21


DCEO OBENG DANKWA DWAMENA

for:

CHIEF FIRE OFFICER

