

In case of reply the number and date of this letter should be quoted



**Ghana National Fire Service**  
**Headquarters**  
**GPS Address: GA-238-0816**  
**P.O.Box 4129**  
**Accra - Ghana**  
**Tel: 0302 772 446**  
**Fax: 0302 772 451**

NFS/.SAF.D/R24.WC/VOL.III/

13

My Ref: No.....

Your Ref: No.....

THE MANAGER  
GHANA RUBBER ESTATES LIMITED  
APIMANIN, W/R

18 ..... SEPTEMBER, 2024

**RENEWAL – FIRE CERTIFICATE (06188 H)**


1. The under listed documents on your premises (Factory) have been inspected by an authorized Fire Inspector for the renewal of your Fire Certificate.
  - i) Previous Fire Certificate
  - ii) Log book
2. Re- inspection of your premises shows that:
  - i) Fire extinguishers installed have been serviced
  - ii) Record of test on fire extinguishers, fire alarm and training entered in the log book has been checked (where appropriate).
3. In addition to the above, you need to provide the following information before the next renewal date:
  - i) Provide the location of the nearest hydrant to the premises
  - ii) Evidence of compulsory Fire Insurance Certificate
  - iii) The quantities of fire facilities installed on premises
  - iv) Confirmation of the type of fire detection and warning system installed (i.e. Battery or Electrical )
4. Management shall ensure that Log book entries are made and installed fire facilities are maintained by a Competent Fire Protection Service Contractor/Provider.
5. Your Fire Certificate is hereby renewed and expires in September, 2025
6. Attached is the new Fire Certificate No.0026251 - H

**NB:**

- FAILURE TO DISPLAY THE FIRE CERTIFICATE IS AN OFFENCE
- FAILURE TO RENEW AN EXPIRED CERTIFICATE IS AN OFFENCE

  
**DANIELLA MAWUSI NTOW SAPONG**  
**DCFO**  
**DIRECTOR FIRE SAFETY**  
**for: CHIEF FIRE OFFICER**

0026251



HIGH RISK

GHANA NATIONAL FIRE SERVICE



# FIRE CERTIFICATE

*This is to certify that*

house number \_\_\_\_\_ of APIMANIN, W/R \_\_\_\_\_ has been issued  
with Fire Certificate for use as PLACE OF WORK (FACTORY) GHANA RUBBER ESTATES  
LIMITED

Having upon inspection satisfied the following requirement as Fire Safety:

### Means of Escape

Type	Number	Location
a) MAIN EXIT	A O D	A O D
b) GFN	2	
c) ES/EDS	6	
d) EL	5	

### Fire Fighting Equipment

Type	Number	Location
a) CO <sub>2</sub> (5KG)	10	
b) DP (6KG)	16	
c)		
d)		

### Fire Hydrant/Source of Water Supply

HYDRANT - \_\_\_\_\_ NIL  
ALTERNATIVE SOURCE OF WATER - UNDERGROUND TANK

### Warning Device(s)

Type	Number	Location
a) DS (BATTERY)	3	
b) CPT	2	
c) SDER	2	
d)		

06188H

**THIS CERTIFICATE IS VALID FOR TWELVE MONTHS**

Dated this 12TH day of SEPTEMBER, 20 24

DCFO DANIELLA MAWUSI NTOW SAPONG

for: **CHIEF FIRE OFFICER**

